

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3725-0638:103

Page 1 of 1

CATEGORY: Door Hardware

LISTEE: Precision Hardware, PO Box 74040, Romulus MI 48174-0040
Contact: *Paul Haeck (734) 326-7500

DESIGN: Models FL-100, FL-1100, ELR-FL-1100, SS-FL-1100 rim type, FL-200, FL-200-LBR, FL-1200, FL-1200-LBR, ELR-FL-1200, SS-FL-1200, surface mounted vertical rod type, FL-300, FL-1300, ELR-FL-1300, SS-FL-1300 mortise type, FL-1600, FL-1600-LBR, ELR-FL-1600, SS-FL-1600, FL-1800, FL-1800-LBR, ELR-FL-1800, SS-FL-1800 concealed vertical rod fire exit devices. Suffix -LBR indicates device without bottom latching mechanism. Suffix -SS indicates signal switch. Prefix -ELR indicates electric latch retraction. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire-rated door hardware for single and double outswinging fire rated doors up to 3 hours. These devices are intended for use on door leaves not exceeding 4' wide by 8' or 10' high.

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 10, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager